

ORDER/NERC/269/2021

BEFORE THE NIGERIAN ELECTRICITY REGULATORY COMMISSION IN THE MATTER OF THE EXTRAORDINARY REVIEW OF MULTI-YEAR TARIFF ORDER FOR ABUJA ELECTRICITY DISTRIBUTION PLC

1.1. Title

This regulatory instrument may be cited as NERC Order on Performance Improvement Plan (PIP) and Extraordinary Tariff Review Application for Abuja Electricity Distribution Plc (AEDC).

1.2. Commencement

The approved PIP and Capital Expenditure ("CAPEX") programme of AEDC shall take effect on the 1st day of July 2021 and shall remain effective until the 30th day of June 2026.

1.3. Context

AEDC applied to the Commission in November 2019 for a review of the provisions for CAPEX in its Multi-Year Tariff Orde ("MYTO") tariffs to support the implementation of its Performance Improvement Plan ("PIP") over the next 5 years. Under the Power Sector Recovery Program (PSRP), it is envisaged that the Commission would implement a robust tariff review process aiming at improving the performance of the Nigerian Electricity Supply Industry ("NESI"). This process involved a review of the capital expenditure allowances in the MYTO model to align with the Performance Improvement Plans (PIPs) of the Distribution Companies (DisCos). The approved PIP and Extraordinary Tariff Application shall form the basis for AEDC to prioritise the implementation of the proposed CAPEX initiatives. The approved PIPs shall also form the basis for defining KPIs for AEDC for the next 5 years by the Commission with emphasis on improvement in energy throughput and improved service delivery to the customers.

As part of the Stakeholder Consultation Process for Extra Ordinary Tariff Review, the Commission held public hearings to consider the applications filed by AEDC in February 2020 and monitored the stakeholders' engagements by AEDC at different locations within its franchise. Based on the feedback received during the consultations and subsequent

AU MA AND COL

deliberations with various stakeholders, the Commission approved the Serviced-Based Tariff (SBT) effective from the 1st of September 2020 to ensure that rates paid by customers align with the quality of service as measured by the daily average availability of power supply over a 60-day reference period. Further updates to AEDC's initial PIP submission have been considered as part of this review to align the PIPs with customer expectations of service commitment by AEDC.

1.4. Summary and Overview of AEDC's Network/Current State

AEDC operates across four states of Nigeria (Kogi, Abuja, Nasarawa, and Niger) over a landmass of 133,000km Sq. comprising of 8,770 km of 33kV and 5,785 km of 11KV line making a total of 14,555 km of medium voltage lines.

AEDC has 277 units of injection substations supplied from the Transmission Company of Nigeria (TCN) across 18 interface transmission stations. The total installed AEDC injection capacity is 2,530MVA interfacing with TCN.

Per the MYTO allocation and Vesting contract, AEDC is entitled to 11.50% of the total generated energy per time within the network. However, in the past four years, AEDC has received on average 14.53% of total energy generated nationally. This is 3.03% more than the MYTO energy allocation. To enhance capacity, AEDC plans to make significant additional investment to upgrade 2,239 km of lines and 188nos. of distribution transformers and 27nos substation transformers to reduce losses in tandem with its Performance Agreement loss commitments.

The Demand Study forecasts conducted in the year 2019 indicate that total demand on the network is 1062.74MW, and subsequently 1,129.4MW, 1,200.63MW, 1,276.92MW, 1,353.21MW and 1,429.50MW for years 2020, 2021, 2022, 2023, and 2024 respectively. Given this capacity growth, AEDC will require investments in the network to adequately plan for the increased demand over the next 5 years.

Following the MAP regulation issued by NERC, AEDC flagged off the MAP in compliance with regulatory expectations. In total 149,953 MAP meters had been installed by AEDC as of November 2020. Implementing the initiative, the Company partnered with three MAP vendors in the initial round and added three MAPs to deploy meters across the franchise area.

1.5. Stakeholder Consultation

AEDC had followed a process for stakeholder consultation as directed by the Commission. Several focused group discussions to harness stakeholder's views on AEDC's services, future expectations, and preferences were conducted with participants representing various customer categories. These engagements are necessary to:



- instill accountability between AEDC and its customers on the services and justification for associated costs and resulting tariffs;
- minimise disputes by engendering understanding and trust between AEDC and its customers;
- provide an opportunity for AEDC to engage with customers on the service improvement investment programme.

Key discussion areas for the stakeholder sessions were:

- Quality and reliability of supply
- · Quality of the metering, billing, and payment process
- · Consumers perception of the processes
- Consumers relationship management
- · Quality of fault complaint and repairs process

1.6. Proposed Outputs:

AEDC proposes to undertake numerous interventions to improve service delivery to the customers. Over the next five years, the proposed interventions will allow AEDC to achieve substantial improvement in service delivery but not limited to the following:

- · Reduce ATC&C losses from the current level of 45% to 19% over 5 years
- Achieve 100% metering of customers by installing 698,606 meters over 3years
- · Improve customer safety and reduce inadvertent accidents
- Increase number of new customers from the current level of 1,214,259 to 1,450,695 over 5 years

Table - 1: Planned Service Improvements Targets

	Planned Sen	vice Improveme	ents		
Îtem	Unit	Current	Service Improvement	Year-5 Target	Variance
Customers	#	1,214,259	236,436	1,450,695	19,47%
ATC&C Loss	%	45	26	19.3	57.35%
Energy Delivered	GWh	4,128	4,134	8,261.3	100.15%
Average Duration of Supply	(Hrs/Day)	17.52	0.46	17.98	2.61%
Average Frequency of Interruptions	#/day	1.12	-0.16	0.96	-14.45%
Average Duration of Interruptions	Hrs/day	6	-2	4	-27.73%

Ar MIT AND Co

1.7. Investment Strategies:

Key strategies proposed by AEDC to attain the targeted service levels over the next 5 year include the following:

- a. Reliability and Quality of Supply Improvement (Technical Loss Reduction) Projects: The implementation of these projects will result in an appreciable reduction of technical losses, improved operational performance, and enhancement of customer service delivery across its franchise area. The projects to be executed are grouped into the following:
 - i. Network Expansion projects
 - ii. Network reconfiguration/rehabilitation
 - iii. Network upgrade
 - iv. Protection, Control & Communication and Metering
- Commercial Loss Reduction Strategies: These initiatives include Revenue protection, replacement of obsolete meters, improving billing accuracy, and deployment of Advanced Metering Infrastructure (AMI).
- c. Collection Efficiency Improvement Strategies: Some of the strategies include; robust Key Account management, full metering of MDAs, and rigorous engagement of MAP scheme to close the metering gap within two years to achieve zero % collection loss.
- d. Enhance Operational Efficiency and Flexibility: Several utility-specific technology tools will be deployed over the PIP horizon. Example of these tools include:
 - i. Geographic Information System GIS
 - ii. Incident Recording & Management System (IRMS)
 - iii. SCADA for HV and MV
 - iv. Outage Management Systems (OMS)
- Customer Service Performance Improvement Strategy: To attain full compliance with regulatory service delivery standards whilst providing real-time customer satisfaction and achievement of excellence operations.
- f. Furthermore, AEDC is exploring several innovative ideas to deliver significant improvement in service delivery and value creation. Some of these initiatives include:
 - Distributed Energy Solutions Strategy to facilitate the development of business models, which support the delivery of energy to augment grid supply;
 - Abuja 24/7 initiative focused on the phased deployment of embedded generation and franchise model towards service improvement
 - iii. Health Safety and Environmental Improvement Initiatives;
 - iv. Stakeholder Communications and Engagement Strategies;

AWAA AM CA

	Table -	2: Propos	ed Investment (Technical)			
ltem	Unit	Current	Additions/ Construction	Year-5 Target	Variance	PIP Rehabil i tation	% of Rehabili tation
Network Length 33 kV	km	8,770	1,583	10,352	18%	201	2%
Network Length 11 kV	km	5,785	657	6,442	11%	3,540	61%
Network Length 0.4 kV	km	49,862	2,430	52,292	5%		
MVA distributions transformers	MVA	5,280	91	5,371	2%		
# distributions transformers	#	17,331	188	17,519	1%		
MVA Substations transformers	MVA	2,530	390	2,920	15%		
# Substations transformers	#	277	27	304	10%		

	2021	2022	2023	2024	2025	Tota
	N000,000	N000,000	1000,000	4000,000	N000,000	N000,000
Construction and Rehabilitation	6,293	6,293	6,293	6,293	6,293	31,464
Injection Substation	4,948	4,948	4,948	4,948	4,948	24,739
Customer Metering	3,958	3,958	3,958	3,958	3,958	19,788
Network Investment	1,279	1,279	1,279	1,279	1,279	6,395
SCADA ERP	1,112	1,112	1,112	1,112	1,112	5,558
Network Metering	988	988	988	988	988	4,940
Distribution Substation	762	762	762	762	762	3,808
Motor Vehicles	353	353	353	353	353	1,766
Plant and Equipment	217	217	217	217	217	1,084
ICT Investments	112	112	112	112	112	559
HSE, Safety Equip, PPE	41	41	41	41	41	205
Others	39	39	39	39	39	197
Work Tools	23	23	23	23	23	117
Security	10	10	10	10	10	50
Network Maintenance	10	10	10	10	10	49
Total	20,144	20,144	20,144	20,144	20,144	100,720



2.0 Commission's Review

- 2.1. The Commission's Guideline for PIP Application established criteria for AEDC to prepare an output-based plan that sets out the service improvement output targets over the planning horizon of 5 years. This plan includes the programs and activities that will lead to the realisation of those outputs, the human and material resources required, the projected costs and analysis of the risk factors, and the proposed mitigation measures. AEDC's PIP and Extraordinary tariff review application was exposed to a Public Hearing and consultation presided over by a panel of three commissioners in line with the Business Rules of the Commission and the "Regulations on Procedure for Electricity Tariff Reviews in the Nigerian Electricity Supply Industry" in February 2020. The Hearing provided an avenue for customers, interested parties, and expert intervenors to critically examine AEDC's proposal and the associated expected improvement in service levels. AEDC was further directed to conduct stakeholders' (customers') engagements at various locations within its franchise area which were attended to and monitored by the staff of the Commission.
- 2.2. Following the outcome of the public consultation, the Commission had vide Order NERC/198/2020 required AEDC to update its PIP and Extraordinary Tariff Review Application by disaggregating its respective service areas and/or customers per quality of service in order to align rates payable by customers with the quality of supply ("service-based tariffs"). A further review of AEDC's updated submission was considered using the following criteria:
 - i. completeness and consistency of the description of each component of the PIP;
 - ii. compliance of each component with the Guidelines for preparation of PIPs issued by the Commission;
- analysis of expected results/outcomes from the implementation of each component including the mitigants provided for addressing identified challenges that may hinder the achievement of target;
- thorough price benchmarking and other relevant approaches to the estimation of resources (physical amounts and related OpEx and CapEx) for each component;
- v. determining if the cost and timeline for delivering the output is efficient;
- vi. assessing the efficiency of the proposed financing arrangement;
- vii. analysing the level of technology/modernization leap proposed going forward;
- viii. determining and analysing the overall level of efficiency improvement proposed.

3.0 Results of the Review

The Commission, having considered AEDC's PIP and Extraordinary Tariff Review Application in line with the provision of EPSRA and relevant regulations, approved the PIP and CAPEX programme over 5 years as provided in Table – 5 and Table – 6 below. Summary of approved projects for Year-1 and Year-2 are also provided in Table – 7, while

for ALA AMO De

a detailed list of approved projects for Year-1 and Year-2 are provided in Appendices 1 and 2 respectively.

Table - 4: Approved 5-year PIP and CAPEX Programme

Year	2021	2022	2023	2024	2025	Total
	Period - 1	Period - 2	Period - 3	Period - 4	Period - 5	Period 1 - 5
	N000,000	N000,000	N000,000	N000,000	N000,000	N000,000
Annual Approved CAPEX	15,197.41	15,197.41	15,197.41	15,197.41	15,197.41	75,987.03

Table - 5: AEDC's Approved 5-year PIP and CAPEX Programme

5-Year Approved PIP	
	N000,000
Total CAPEX	75,987.0
Distribution Network Capex	47,402.0
Construction of 33kV Feeder	9,777.0
Rehabilitation of 33kV Feeder	2,861.6
Construction of 11kV Feeder	3,470.8
Rehabilitation of 11kV Feeder	2,464.1
Construction of 0.400kV Feeder	2,147.8
Distributions transformers (plan)	2,861.6
MVA Substations transformers (plan)	23,819.1
ATC&C Loss Reduction Plan (total)	
Customer Service Improvement Plan	2,384.6
IT Investments (SCADA+GIS+ERP+HSE)	17,950.8
SCADA Initiatives	10730.9
GIS Improvement	225.0
ERP System Infrastructure	2225.7
HSE Initiatives	1669.2
AMI Network Metering	3100.0
Customer Metering Capex	
Network Metering Capex	2,289.2
Others	5,960.3



Table - 6: AEDC's Approved PIP and CAPEX Programme for 2021 and 2022

Approved PIP	2021	2022
	N000,000	N000,000
Total CAPEX	15,197.4	15,197.4
Distribution Network Capex	8,545.4	8,903.8
Construction of 33kV Feeder	1,602.0	1,717.0
Rehabilitation of 33kV Feeder	825.8	432,5
Construction of 11kV Feeder	626.8	761.5
Rehabilitation of 11kV Feeder	580.8	547.2
Construction of 0.400kV Feeder	432.7	426.5
Distributions transformers (plan)	1,145.1	1,088.3
MVA Substations transformers (plan)	3,332.2	3,930.9
ATC&C Loss Reduction Plan (total)		
Customer Service Improvement Plan	20.0	476.9
IT Investments (SCADA+GIS+ERP+HSE)	1,710.2	2,489.0
SCADA Initiatives	1500.0	1000.0
GIS Improvement	0.0	90.0
ERP System Infrastructure	150.0	445.1
HSE Initiatives	0.0	333.8
AMI Network Metering	60.2	620.0
Customer Metering Capex		
Network Metering Capex	997.4	1,291.9
Others	3,924.5	2,035.8



4.0 Annual Update of PIPs

AEDC shall be required to provide an annual update to the PIP to reflect the proposed investment programme as part of the Minor Review of Tariffs on a continuous basis. The Commission recognizes this PIP as a dynamic roadmap of where AEDC envisions to be in the next five (5) years and will continue to evolve in alignment with market development and changes to the operating environment. AEDC may invest more than the indicated annual CAPEX figure in any particular year on account of front-loading proposed future investments or due to the unanticipated critical investment needs subject to the approval of the Commission.

5.0 Front-loading of CAPEX

AEDC is at liberty to front-load its CAPEX programmes to attain accelerated service improvements. Front-loading of CAPEX programme in any year shall not exceed annual CAPEX for the following year in line with the framework for continuous update of the PIPs.

6.0 CAPEX Clawback

Annual CAPEX provisions that are unutilized or imprudently expended shall be clawed back during Minar Reviews of Tariffs in line with the requirements of Section 7(a) of Regulations on Procedure for Electricity Tariff Reviews in the NESI.

7.0 Commencement and Effectiveness

The approved PIP and CAPEX programme of AEDC shall take effect on the 1st day of July 2021 and shall remain effective until the 30th day of June 2026.

8.0 Signature

Dated this 29th day of April 2021

Sanusi Garbo

Chairman

Dafe C. Akpeneye

Commissioner

Appendices





Appendix 1 - Details of Planned 2021 Investments for Abujo Electricity Distribution Company.

Pro	Project Type: Construction of 33kV Feeder	V Feeder			
淮	Project Description	Location	Route Length (km)	Project Completion Date (MM-YY)	Expected Impact in MW)
	33KV Construction	From 100MVA 132/33kV Katampe 3 TS to 33/11kV Injection substation at Karshim IbrahimStreet Wuse II by Turkish Internation School	6.9	Jul-21	15,00
ы	33KV Construction	Apa TS to 2x15MVA Injection substation by Fraser Suite Central Business District Abuja	5	Aug-21	
Eu)	33KV Construction	From 100MVA 132/33kV Katampe 3 TS to Ministers quarters Mabuchi	7.0	Sep-21	13.50
44	33KV Construction	From 100MVA 132/33kV Katampe 3 TS to Oanda filling station along Kubwa expressway	7.6	Jul-21	15,00

0-	7	00	-0	10
33KV Construction	33KV Construction	33KV Construction	33KV Construction	33KV Construction
Karu TS ta Kpeyegyi	Ajackuta to Ajegwu.	From Kukwaba TS to Shoprite along Sheu Musa Yaradua express way and Airport junction to Lugba Gossa along Sheu Musa Yaradua express way	Leleyi, Gwari 1, 2 and 3.	Kukwuaba, Lugbe, Kuje
6.0	10.0	Ξ	7	10
Jul-21	Aug-21	Jul-21	Jun-21	Jul-21
15.00	10.00	5.00	5,00	5.00
	33KV Construction Karu TS to Kpeyegyi 6.0 Jul-21	33KV Construction Karu TS to Kpeyegyi 6.0 Jul-21 33KV Construction Ajackuta to Ajegwu 10.0 Aug-21	33KV Construction Karu TS to Kpeyegyi 6.0 Jul-21 1 33KV Construction Ajackuta to Ajegwu 10.0 Aug-21 1 33KV Construction From Kukwaba TS to Shoprite along Sheu Musa Yaradua express way and Ajrport junction to Lugba Gossa along Sheu Musa Yaradua express way	33KV Construction Ajackuta to Ajegwu 10.0 Jul-21 33KV Construction From Kukwaba TS to Shoprite along Sheu Musa Yaradua express way and Ajrport junction to Lugbe Gossa along Sheu Musa Yaradua express way 33KV Construction Leleyi, Gwari 1, 2 and 3. 7 Jun-21





12	13	4	5
33KV Construction	33KV Construction	33KV Construction	33KV Construction
From Zango TS to Obajana junction and A.B.U on Isanlu makutu	Keffi to Uke/Masaka	Nasarawa Toto	New Nyanya
29.5	11.0	4.0	9.5
Jul-21	Jul-21	Jul-21	Aug-21
5.00	15.00	4.50	27,00
	From Zango TS to Obajana 29.5 Jul-21 makutu	From Zango TS to Obajana 29.5 Jul-21 junction and A.B.U on Isanlu makutu Keffi to Uke/Masaka 11.0 Jul-21 1:	33KV Construction From Zango TS to Obajana 29.5 Jul-21 junction and A,B,U on Isanlu makutu 33KV Construction Keffi to Uke/Masaka 11.0 Jul-21 1:

3	Project Type: Rehabilitation of 33kV Feeder	of 33kV Feeder				
*	Project Description	Type of Rhabilitation	Location	Route Length (km)	Project Completion Date (MM - YY)	Expected Impact in MW)
-	33kV Rehabilitation	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	From Central Area TS to Berger Roundabout	6.2	Jun-21	10.00
N	33kV Rehabilitation	Reconductoring	Frram Maitama Minister Hill 33/11kV Injection Substation to 33/11kV Injection Substation by Karshim Ibrahim Street Wase 2	2.8	Jul-21	15,00

-0	00	7	0	Ü	4	ω
33kV Rehabilitation	33kV Rehobilitation	33kV Rehabilitation	33kV Rehabilitation	33kV Rehabilitation	33kV Rehabilitation	33kV Rehabilitation
Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles occessories etc	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring, Replacement of Pales, Replacement of Pales accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring	Recanductoring
From Apo TS to Nigeria Security Printing and Mining Garki	Minna	From Minna TS to Lapai town	Apo, lugbe, Kuje	From Apo TS to Lokogama and environs	From 33/11kV Injection Substation by Maitama Rounaboud along IBB way Wuse 2 to 33/11kV Injection Substation by El-Hamin International School along IBB way Maitama	From 33/11kV Injection Substation by Annur Masque along IBB way Wuse 2 to 33/11kV Injection Substation by Maitama Roundabout along IBB way Wuse 2
7.1	20	100	62,8	32	2.6	12
May21	Jun-21	Jun-21	Jun-21	May-21	Jul-21	Jul-21
5.00	2.00	2.00	5.00	5.00	15.00	15.00





	0	out
		V Rehabilita
accessories etc	Replacement of Poles, Replacement of Poles	Reconductoring,
		Lafia
		8.4
		Jun-21
	5.00	

3	Project Type: Construction of 11kV Feeder	V Feeder			
*	Project Description	Location	Route Length (km)	Project Completion Date (MM - YY)	Expected Impact in MW)
-	11kV Construction	Apo TS to 2x15MVA Injection substation by Fraser Suite Central Business District Abuja	=	Aug-21	27.00
ю	11kV Construction	Trade More	10	Juli 21	10.00
ယ	11kV Construction	Sabon Wuse	9.1	Aug-21	10.00
4	4 11kV Construction	Lugbe	4.6	Jun-21	5.00
Un	11kV Construction	Minna	7	Jun-21	5.00
٥	11kV Construction	Ministers quarters Mabushi	U	Sep-21	13.50
5	Total		47		201100

*	P	5
Project Description	oject Type: Rehabilitation of	smbution Network; lines
Type of Rhabilitation	n of 11kV Feeder	
Location		
Route Length (km)		
Project Completion Date (MM - YY)		
Expeded Impact in MW)		

N	ω	4.	Gi	0-	N
T1kV Rehabilitation	11kV Rehabilitation	1 I kV Rehabilitation	11kV Rehabilitation	13kV Rehabilitation	11kV Rehabilitation
Reconductoring, Replacement of Pales, Replacement of Pales accessories etc	Reconductoring, Replacement of Pales, Replacement of Pales accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc	Reconductoring, Replacement of Poles, Replacement of Poles
From 33/11kV Injection substation to supreme court Asokaro and its environs	Suleja	From Bido TS to Army Barracks Bida	GRA, Minna	Minno	Keff
2.8	N	80	15	30	On.
Jul-21	Jun-21	Jun-21	Jun-21	Jun-21	Jun-21
5,00	10.00	3.00	3.00	2.00	3.00
	T1kV Rehabilitation Reconductoring, Replacement of Pales, Injection substation Replacement of Pales to supreme court accessories etc. Asokaro and its	T1kV Rehabilitation Replacement of Pales, Replacement of Pales, Replacement of Pales, accessories etc accessories etc Asokaro and its accessories etc Suleja T1kV Rehabilitation Replacement of Pales, accessories etc T1kV Rehabilitation Reconductoring, Replacement of Pales, accessories etc T1kV Rehabilitation Reconductoring, Replacement of Pales, accessories etc T1kV Rehabilitation Reconductoring, Replacement of Pales, accessories etc	T1kV Rehabilitation Replacement of Pales, Replacement of Pales, Replacement of Pales, accessories etc Reconductoring, Replacement of Pales, Replacement of	T1kV Rehabilitation Reconductoring, Replacement of Pales, Army Barracks Bida	11kV Rehabilitation Reconductoring, Replacement of Poles accessories etc Replacement of Poles, Replacement of





Total	00
<u>u.</u>	11kV Rehabilitation
	Reconductoring, Replacement of Poles, Replacement of Poles accessories etc
	Lafia
145	5
	Jun-21
	8.00

Pro	Project Type: Construction and Rehabilitation of O.400kV Feeder	Rehabilitation of 0.40	10kV Feeder			
*	Project Description	Type of Project	Location	Route Length (km)		Project Completion Expected Impact in MW) Date (MM - YY)
-	Construction of Lower Voltage Network in critical areas across AEDC franchise areas	Construction	FCT, Kogi, Niger and Nasarawa States			Sep-21
N	Rehabilitation of Lower Voltage Network in critical areas ocrass AEDC franchise areas	Rehabilitation	FCT, Kogi, Niger and Nasarawa States			Sep-21
Total				0	_	

*	Proj
Name of	ribution I led Type
Substation	New Constru
Transformation Voltage (kV)	ns chon, Reinforcem
Rating -	ent and Sta
Type of work (New Construction or Replacement)	ndardisation of Dist
Location	rubution Sub-s
Quantity	dation
Project Completion Date (MM - YY)	
Expected Impact in MW	

Total	AER AER
9_	120Nos 500kVA Relief Substations and replacement across AEDC franchise areas
	33/0.415
	900
	Construction
	Niger and Nasarawa States
120	120
	Nov-21
	60,00

30 3	电	_	12	Cui	4
Project Type: Construction, Reinforcement and Standardisation of Injection Substation	Name of Substation	Completion of the ongoing 33/11kV 2X15MVA Televeras 4 Injection substation at Central Area by Fraser Suites in Central Business District	Proposed construction of 2x7.5MVA, 33/11kV injection substation at Ministers quarters Mabuchi (Recovery and Replacement of 60No 33KV/11KV Transformers)	Proposed construction of additional 1 x 7.5MVA, at Apo Resettlement	Rehabilitation of 2X15MVA 33/11kV Field base injection substation
cement and Standardisation	Location	Completion of the ongoing 33/11kV 2X15MVA Injection substation at Central Area by Fraser Suites in Central Business District	From 100MVA 132/33kV Katampe 3 TS to Ministers quarters Mabuchi	Apo Resettlement	Suleja
of Invinction	Rating - MVA	30	15	7.5	30
n Sub-station	Type of work	New Construction	New Construction	Additional Power Transformer	Rehabilitation
	untis of	-			-
	Project Completio n Date (MM - YY)	Aug-21	Sep-21	Sep-21	Jun-21
	Expected Impact (MW)	27.00	13.50	6.80	10.00





T	0 -	ø	00	7	0-	Ü
DWAY OLCON WILLIAM	Replacement of failed 33/11kV 2.5MVA with	Installation of 5MVA, 33/11kV substation at FUT Minna	Proposed installation of 5MVA, 33/11kV Transformer and Resucitation of Distribution substation to Nasarawa Toto community	Upgrade from Tno 5MVA 33/11kV S/S to 2X7.5MVA and radiation of additional 11kV feeders at Madalla/Zuba from Suleja TS	Completion of abandoned 2 x 15MVA, 33/11kV injection substation at New Nyanya Nasarawa State and radiation of 33kV feeder from 2X60MVA 132/33kV Karu TCN	Proposed Installation of additional 1X15MVA Transformer at M44 33/11kV Injection substation Gwarinpa.
	CBN Minna	FUT Minna	Nasarawa Toto	Suleja	New Nyanya	Gwarinpa
	Uh	i h	Üt	15	30	in.
	Additional Power Transformer	Additional Power Transformer	Additional Power Transformer	Additional Power Transformer	Additional Power Transformer	Additional Power Transformer
	- 1	===	2			
	Jun-21	Aug-21	Jul-21	Nov.21	Aug-21	Sep-21
	4.5	4.5	4.50	13.50	27.00	13.50

Network: Standardisation of Existing Injection Substations (33/11kV)

Project Type: Replacement of Switch Gears, Control Panel and Protection Equipment

3	-	N	ယ်	4	(A	0	N
None of Substitution	Replacement and Rehabilitation of 11kV switch gear at L142 X 7.5MVA Lafia Injection substation	Replacement of 1 1kV defective RMU in the FCT regions	11kV indoor breakers incomer at Suleja, Lakoja, Minna, New Nyanya and Apo Resettlement	11kV indaar breakers autgoing Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	33kV autdoor line breakers Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	Line cantrol panel Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	Power transformer protection & control panel
Description	11kV indoor Control Panel	11kV autdoor circuit breaker	11kV indoor Control Panel	11kV Indoor Control Panel	33kV autdoor circuit breaker	Line control panel	33kV Isolator
Location	Lafia	FCI	33/11kV Injection Substations at Suleja, Lokoja, Minna, New Nyanya and Apa Resettlement	33/11kV Injection Substations at Suleja, Lakoja, Minna, New Nyanya and Apo Resettlement	33/11kV Injection Substations at Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	33/11kV Injection Substations at Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	FCT, Kogi, Niger and Nasarawa States
Quantity	7	20	10	8	12	12	8
Completion Date (MM -	Jul-23	Jul-21	Jul-21	Jul-21	Jul-21	Jul-21	Jun-21
Impact	4.00						





Customer Service Improvement Plan

	4-	0 -	اد م	- 4	ω	2		0-	٥	0
Total	control cables (2.5mmx 7 core) for company use	control cables (4mm x 4core) for company use	control cables (2.5mm x 12core) for company use	control cables (2.5mm x 24 core) for company use	33kV auto reclaser Company wide	Smart oc/ef relay microprocessor with broken conductor NR relay. Company wide	Transformer all for company use	200Amp battery bank, 9 per set company wide	110v Tripping unit; battery charger Company wide	Procument of Instrument Transformers (CTs and VTs) for use in our Injection substations at Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement
						Relay	Transformer oil	battery bank	Tripping unit	Current Transformer & Voltage Transformer
	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kagi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	FCT, Kogi, Niger and Nasarawa States	33/11kV Injection Substations at Suleja, Lakoja, Minna, New Nyanya and Apo Resettlement
4451	1000	1000	1000	1000	30	80	180	30	16	12
	May-21	May-21	May-21	May-21	Jun-21	Jul-21	May-21	Jun-21	Jul-21	Jul-21
							<u>I</u>			

#e		
* Nome	Procurement of CRM for enhancement of customer services	Total
Quantity	5.5	-
Project Completion Date (MM - YY)	May-21	

II Inv	a. Z	- ×	
nvestments (SCADA)	Name	upervisory Control and Data cquisition (SCADA)	Total
	Description		
	Project Completion Date (MM - YY)	Sep-21	
	Expected Impact		

z	Network Metering (Smart Meters)			
*	Project Description	Description	Quantity	723
-	Smart Feeder Meters for Manned Sub Stations	Z _n	917	
10	Smart Feeder Maters for unmanned Sub Stations	New	128	
w	Smart Feeder Meters for station service consumption	Zew	157	
4	MD HV metering Panel	Zlew	40	

Other Service Improvement Plan





3	12	=	10	9	00	7	0	U	4	ω	2	-	*
Remote manitoring and remote control of 415V distribution transformer (DT) and artificial Jul-21 intelligence and data mining	Procument of Clamp of Ammeter for RPU and Transformer Load readings	Outage detection and notification system (FCI)	Avometer for company use	Fluke clamp on anmeter for company use	80kV pressure tester for company use	Procurement of 34 feet and 28 feet (HT & LT) fibre ladders across AEDC franchise areas	IT Warktools (Laptops, Desktops, UPS & Accessories)	Heavy duty crane-HAIB -15 tannes, 3+ boom, 1-5ft bucket	Vehicles	Non-technical Capex	Proposed Construction of Transformer Repair Workshop	Construction of AEDC Office at Zone 6 + fixtures (WIP)	Vame
Jul-21	May-21	May-21	May-21	May-21	May-21	May-21	May-21	May-21	May-21		Jul-21	Sep-21	Project Completion Date (MM - YY)

Appendix 2 - Details of Planned 2022 Inventments for Abuja Electricity Distribution Company

*	Project Typ	Distributio
Project Description	pe: Construction of 33kV Feeder	o Network: lines
Location		
Route Length (km)		
Project Completion Date (MM - YY)		
Expected Impact in MW)	101	

_	2	Eu)	4	Ch Ch	0
Proposed construction of 33kV dual feeders to 1x15MVA 33/11kV M44 Injection substation Gwarinpa and Dawaki from the proposed 2x60MVA Dawaki Transimssion station	Proposed Construction of 33kV Feeder to the 2x15MVA 33/11kV M2 Injection substation Jabi from the proposed 2x60MVA Lugbe Transimssion station	Proposed Construction of 33kV Feeder to Godab Estate from the proposed 2x60MVA Dawaki Transimssion station	Proposed construction of 33kV feeder from the proposed 2x60MVA, 132/33kV Lugbe Transmission station to feed the proposed 4X15MVA Idu injection substations and radiation of 5No 11kV autgaing feeders	Proposed Construction of 33kV Feeder to 2x15MVA 33/11kV M42 Injection substation Gwarinpa from the proposed 2x60MVA Dawaki Transimssion station	Proposed construction of 33kV feeder from the proposed 132/33kV Lokagama Transmission station to feed the proposed 2X15MVA Lokagama injection substations and radiation of 2No 11kV outgoing feeders
Gwarinpa	Jabi	Godab	Idu Industrial Layout	Gwarinpa	Lokogoma
12.00	11,20	9.69	25.00	7.10	14.33
Sep-22	Sep-22	Sep-22	Sep-22	Sep-22	Sep:22
15,00	15.00	15.00	15.00	15.00	15.00





1	CO	.0	10	=	12	13	4
Proposed construction of 33kV line to River Park Estate Lugbe from the proposed 2X60MVA 132/33kV, Lugbe Transmission station	Proposed construction of 33kV line to Lugbe Across Lugbe from the proposed 2X60MVA, 132/33kV, Lugbe Transmission station	Proposed construction of 33kV feeder to feed Kuje Town and evirons from the proposed 2x60MVA, 132/33kV, Kuje Transmission station	Proposed construction of 33kV feeder to feed Premium farm and evirons from the proposed 2x60MVA Kuje Transmission station	Proposed contruction of 33kV line from the proposed 2x60MVA 132/33kV Lugbe Transmission station to Lugbe 2x15MVA.	Proposed construction of 33kV dual lines from 2x60MVA 132/33kV Karu TS to Mararaba to deload feeder K4	Proposed Construction of 33kV feeder from the proposed 2x60MVA 132/33kV Transmission station, Dawaki to Sokale Duste	Proposed extension of 33kV feeder from NTA roundabout to Ekpata 2x15MVA Injection Substation Lokoja main
River Park Lugbe	Lugbe Across	Kuje Town	Premium Farm Kuje and environs	Lugbe	Karu, Mararaba, Lugbe	Sokale Duste	Lokoja
12,70	7.10	6.26	10.30	4.40	3,20	7.30	2.00
Sep-22	Sep-22	Sep-22	Sep-22	Sep-22	Sep-22	Sep-22	Aug-22
15.00	15.00	15.00	15.00	15.00	15.00	15.00	5.00

i.s	7.0
Proposed Construction of 10km 33kV feeder from 1x60MVA Ajaokuta TS to Ajegwu junction including 4nos tower (Phase 2)	Proposed Construction of 33kV double circuit to NIPP & Obi Awe feeder from 2x60MVA, 132/33kV Akurba transmission station Lafia, Nasarawa
Ajaokuta	Lafia, Nasarawa
10.00	14.40
Sep-22	Aug-22
10.00	15.00
Sep-22	Aug-22

3	Project Type: Rehabilitation of 33kV Feeder	V Feeder					
75	Project Description	Type of Rhabilitation	Overhead/ undergroun d	Location	252	Route Length (km)	ngth Completion n) Date (MM -
met	Reconfriguration of 1.34 Kukuwaba TS to deload Feeder 3 from Central area TS	Reconductoring, replacement of Poles, replacement of Poles accessories etc	Overhead	Cestral Area	-	1.20	
153	Rehabilitation of 33kV feeder 9 from Central area TS	Reconductoring, replacement of Poles, replacement of Poles accessories etc	Overhead	Central Area	çu	3,90	90 Jul-22
ယ	Rehabilitation of 33kV Bwari feeder from 2x60MVA 132/33kV Kubwa TS	Reconductoring, replacement of Poles, replacement of Poles accessories etc	Overhead	Bwari	06	8.10	.10 Jul-22
4-	Rehabilitation of 33KV feeder from Nasarawa to Mararaba Udege	Reconductoring, replacement of Poles, replacement of Poles	Overhead	Mararaba Udege	63	25.00	15.00 Jul.22





3	Project Type: Construction of 11kV Feeder	Feeder					
4:	Project Description	Overhead/ underground	Conductor Size (mm2)	Location	Route Length (km)	Project Completion Date (MM - YY)	Expected Impact in MW)
-	Proposed construction of 2No 11KV feeder to Lakagama from the proposed 2x15MVA, 33/11KV Lakagama Injection substation.	Overhead	150 mm2	Lokogoma Abuja	8.0	Aug-22	10.00
12	Proposed construction of dual 11kV feeders from the 2x15MVA Lokoja main Injection Substation to feeds Ganaja and Natako	Overhead	150 mm2	Lokoja	24.0	Aug-22	10.00
ω	Proposed construction of dual 11kV feeders from the 2x15MVA L16 Lafia Injection Substation to feeds commercial viable customers within Lafia	Overhead	150 mm2	Lafia	13.0	Aug-22	10.00
4	Construction of Dual 11kV feeders within the state to improve supply to the commercial viable customers	Underground	150 mm2	Minna	14.0	5ep-22	10.00
Û	150-7575	Overhead	150 mm2	Minna	12.2	Aug-22	5.00

ij	
	33/11kV Power House Injection substation Minna
N	
	1
100	

3 0	4:	(11) (11)	N	ω	- 4
Distribution Network: lines Project Type: Rehabilitation of 11kV Feeder	Project Description	Replacement of bad 11kV underground cable on RM 9A from 2x15MVA 33/11kV C2 Injection substation Mailama	Rehabilitation of 11kV feeder 1, 2, 3 and 4 from 2x15MVA 33/11kV, B32 Injection substation Zone 5, Berger	Rehabilitation of 11kV Distribution network for Lafta/Obi Area Office	Rehabilitation of 11kV Dutse Kura feeder from 2x15MVA 33/11kV Zaramai Injection substation Minna
1kV Feeder	Type of Rhabilitation	Replacement of bad underground cable and termination kits	Reconductoring, replacement of Poles, replacement of Poles accessories etc	Reconductoring, replacement of Poles, replacement of Poles	Reconductoring, replacement of Poles, replacement of Poles
	Overhead / undergrou	Undergro	Overhead	Overhead	Undergro und
	Conduct or Size (mm2)	150 mm2	150 mm2	150 mm2	150 mm2
	Location	Maitama	Вегдег	Nasarawa	Minna
	Route Length (km)	1.6	12	20	20
	Project Completion Date (MM - YY)	Jul-222	Jul-22	Jul:22	Jul-22
	Expected Impact in MW)	2.00	5.00	2.00	2.00





	(A)
	Rehabilitation/Maintenance of 11KV Tudun Fulani feeder Bosso
accessories elc	Reconductoring, replacement of Poles, replacement of Poles
	und
	150 mm2
	Minna
	Ŋ
	Jul-22
	2:00

3	Project Type: Construction and Rehabilitation of 0.400kV Feeder	habilitation of 0.400	kV Feeder		
*	Project Description	Type of Project	Overhead/ underground	Conductor Size (mm2)	Conductor Location Size (mm2)
-	Rehabilitation of 11kV Distribution network for Lafta/Obi Area Office	Rehabilitation	Overhead	150 mm2	150 mm2 Nasarawa
N	Rehabilitation of Low Voltage Network in critical areas ocross AEDC franchise areas	Rehabilitation	Overhead	 150 mm2	150 mm2 FCT, Kogi, Nasarawa and Kogi
ω	Construction of Low Voltage Network in critical areas across AEDC franchise areas	Rehabilitation	Overhead	 150 mm2	150 mm2 FCT, Kogi, Nasarawa and Kogi

			4	7	D
			Name of	oject Type:	stribution 1
			e of Substation	New Construction,	Vertwork: stations
				Reinforcement and Stan	
	Voltage	otion	Transform	andardisation of L	
	KVA	- Bu	Rati	Xistrubu	
Replaceme	Constructio	work (New	Type of	tion Sub-station	
			Location	8	
	_	ijγ	Quant		
3	ion Date	Complet	Project		

_		-
	across AEDC franchise	Construction of 100Nos 500kVA Relief Substations
		33/0.415
	1	500
3	Constructio	New
Niger	Nasarawa and	FCT, Kogi,
	3	100
		Sep-2

	****			0.00	- 1950
100	- to	:	N	ω	4
Project Type: Construction, Reinforcement and Standardisation of Injection Sub-station	Name of Substation	Proposed construction of 4X15MVA 33/11kV Injection Substation at Idu Industrial layout from the proposed 2X60MVA Lugbe Transmission station	Proposed construction of 2X15MVA 33/11kV Injection 2X15MVA 33/11kV Injection Substation in Lokogoma from the proposed 2X6GMVA, 132/33kV, Lokogoma Transmission station	Upgrading of Karshi 2.5MVA to 5MVA 33/11KV unmanned transformer, RMU CT Relay operated (two mains & one extention) & 185MM2 cable	Replacement of faulty 1x7.5MVA with 1x15MVA at 2x7.5MVA NIPP Injection Substation Kubwa
cement and	Location	ldu Industria I layout	tokogo ma	Korshi	Kubwa
Standar	Rating - MVA	60	30	5	15
fisation of Inject	Type (Manned/un manned)	Manned	Manned	Unmanned	Manned
ion Sub-station	Type of work	New Construction	New Construction	New Construction	New Construction
	units of	<u>+</u>	2		-
	Project Completion Date (MM - YY)	Nov-22	Nov-22	Aug-22	Jul-22
	Expected Impact (MW)	57,00	27.00	4.50	13.50





0	Un
completion of installation of TR2 Bwari	Reactivation of Zarumai 15MVA 33/11KV transformer, tranformer oil
Bwari	Zarumai , Minna
15	5
Manned	Manned
New Construction	Rehabilitation
-	
Aug-22	Jul-22
13.50	13.50

		_						
	0	3	# 3		13	ω	4	(n
transformer, transformer oil completion of installation of	TR2 Bwari	Network: Standardisation of Existing Injection Substations (33/11kV)	Project Type: Replacement of Switch Gears, Control Panel and Protection Equipment Warne of Substation Description	HV Indoor CT	HV Indoor VT	300mm Single Care Cable	IV CT (100/5)	LV CT (200/5)
, Minna	Bwari	ting Injection	itch Gears, C	[4]				
5 5	15	Substati	ontrol R					
Manned	Manned	ons (33/11kV)	anel and Protect					
Rehabilitation	New Construction		Description	Q	M	Cable	Q	Q
- e	-		Location	FCT, Kagi, Nasarawa, Niger and Kagi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi
Juk22	Aug-22		Quantity	Ch.	Ċ,	600	10	ĭō
13.50	13.50		Project Completion Date (MM -	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22

0	7	00	o	10	1	12	ü
[V C1 [300/5]	LV CT (500/5)	Filteration machine BIG (flow rate 2,400 LPH)	Filteration machine SMALL (Flow rate 600LPH)	SF6, gas leakage detector	Transformer ail sealant (Pawer patch)	Transformer oil	Oil sample test equipment
1	IJ	Filteration Machine	Filteration Machine	SF6	Transformer Oil	Transformer Oil	Oil tester
FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kog), Nasarawa, Niger and Kogi	Suleja, Lokoja, Minna, New Nyanya and Apo Resettlement	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi
10	30	2	<u> </u>	2	20	180	٥
Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22





4	5	16	17	ŏ	19	20	21
Smart relays OC/EF & broken conductor NR	Smart relays OC/EF & broken conductor MICOM	Silica gel 200kg	11KV panel (2 Incomer, 1 coupler & 6 Outgoings)	RMU CT Relay operated (theo mains & ane extention)	Power Transformer control Panel	Line Control Panel	Repair of power transformer (15MVA 33/11KV)
Relay	Relay	Silico	Panel	RMU	Control Panel	Control Panel	Power Transformer
FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	PCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasorawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi
4	4	25	(A	12	22	ω	=
Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22	Jul-22

24		23	22
Procurement of feeder pillars of different capacities	Fisptorial plug terminatia 185mm2 33kv for Wuye Inj. s/s	Fisptorial plug terminatio 240mm2 33kv for 833 inj. s/s	Resuscitation if Lifecomp 7.5MVA transformer, bushing, transformer all
Feeder Pillar	Plug terminator	Plug terminator	Transformer Burshing
FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kogi	FCT, Kogi, Nasarawa, Niger and Kagi	FCT, Kogi, Nasarawo, Niger and Kogi
112	- 2	-	_
Jul-22	Jul-22	Jul-22	Jul-22





a. 7
roposal for the GIS mapping of HT/LT listribution network asset
Jul-22

Š.	Network Metering (Smart Meters)			
**	Project Description	Description	Quantity	Project Completion Date (MM - YY)
-	Meter Accuracy Mobile Test Equipment	New	20	Aug-22
2	DI Metering	New	400	Aug-22
ш	Prepaid DT Metering	New	300	Aug-22
4	33kV Boundary Meters	New	13	Aug-22
5	11kV Boundary Meters	Now	15	Aug-22
0	Grid Energy Meters	New	120	Aug-22
7	Metering Tool Box	New	180	Aug-22
00	Android Tablet for Meter Commissioning	New	120	Aug-22
0	MD Energy Meter	New	700	Aug-22
10	2.5mm X 12 Core Cables	New	10000	Aug-22
=	Whole Current Energy Meter	New	400	Aug-22
€	Other Service Improvement Plan			
*	Name	Project Completion	pletion	

-	N	ω	4	140	0	- 54	00
Proposed construction of Transformer Repair/Maintenance Workshop at AEDC central stare, Wuse Zone 5, Abuja	Non-technical Capex	Vehicle for Metering Activities	Procurement of 34 feet and 28 feet (HT & LT) fibre ladders across AEDC franchise areas	Procurement of Chain saw machine for Vegetation Control	Remote monitoring and remote control of 415V distribution transformer (DT) and artificial intelligence and data mining	Outage detection and notification system (FCI)	Procument of Clamp of Ammeter for RPU and Transformer Load readings
Od-22	Oct-22	Od-22	Od-22	Od-22	Od-22	Od-22	Od-22

